

Strojírenský zkušební ústav, s.p., Brno, Česká republika Engineering Test Institute, Public Enterprise, Brno, Czech Republic

## CERTIFICATE

Number: E-30-20440-12

Producer: YU CHI TAIWAN ENTERPRISE CO., LTD.

No. 2, Lane 625, Ming-Yeou Rd., Lu-Chu Dist.

Kaohsiung City, 821, Taiwan

Product.

Stainless steel screw

Type/Model/Specification:

- ø 4.2 mm

- flat head, with furrows, Phillips recess, type 17, collated

- material: stainless steel AISI 316, finish treatment: passivated

- length: (35 to 100) mm

Product identification and findings of the initial-type testing of the product:

see Annex 1 (page 2)

Base of certificate issuance:

Final Report on Initial Type-Testing of the product

30-9775/1 of 2012-11-21

Harmonized standard:

EN 14592:2008, Tab. ZA.1

Strojírenský zkušební ústav, s.p., Engineering Test Institute, Public Enterprise, confirms that performed the initial-type testing of the said product according to the requirement stated in Directive 89/106/EEC, Annex III, (2) (ii), second possibility (corresponds with Government Order 190/2002 Coll. § 5 art. 1 let. b). Final Report containing initial type-testing findings and data on product identification.

Brno, 2012-11-22



Ing. Pavel Štícha Director for Certification

Certificate No. E-30-20440-12.docx; Page 1 / Total pages 2



## Certificate E-30-20440-12, Annex 1

## Product identification and findings of the initial-type testing of the product:

Product	characteristic yield moment $M_{y,k}$ [Nmm]	characteristic withdrawal parameter $f_{ax,k}$ [N/mm <sup>2</sup> ]		characteristic head pull- through parameter f <sub>head,k</sub> [N/mm <sup>2</sup> ]	characteristic tensile capacity $f_{tens,k}$ [kN]	characteristic torsional ratio
		loading across the fibre	loading along the fibre	-		
screw ø 4.2 mm	3 832	15,10	8,46	23,87	4,18	1,92
Characteristic density of wood $\rho_k$ [kg/m³]		360		415		450
Durability (corrosion protection)	stainless steel AISI 316 (Service Class 3 acc. to EN 1995-1-1)					

Intended use: in load bearing structural timber products.

